



LIST OF MATERIALS

1. CURB STOP- Mueller B25204 or approved equal.
2. CURB BOX- Mueller H10346 Service Box With Rod Location
To Be Behind Curb At Property Line
3. COPPERHORN- 5/8 x 3/4 Copper Meter Yoke (check with Public Facilities)
4. WATER METER- Badger Read-O-Matic.
5. OUTDOOR METER REGISTER- Located In The Front Of Dwelling.
-three(3) to five(5) feet in height.
6. SERVICE LINE- Cooper-Soft "K".
1", 1-1/2", 2"

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

[Signature] 6/29/95
DIRECTOR OF DEVELOPMENT SERVICES DATE

WATER / SEWER ENGINEER

DATE

STANDARD DETAIL
TYPICAL HOUSE
CONNECTION
FOR REMOTE READING
WATER METER

REVISIONS:

W
6.00